



# Chandigarh Pollution Control Committee

Paryavaran Bhawan, Madhya Marg, Sector 19-B, Chandigarh-160 019

o/c

No. CPCC/2019/3770

To

Dated: 08.01.2020

The Chairman-cum-Advisor to the Administrator,  
State Level Special Task Force,  
U.T. Chandigarh

**Sub:- Submission of Monthly report of District Level Special Task Force regarding.**

Sir,

This is in reference to order dated 7<sup>th</sup> August, 2018 passed by Hon'ble National Green Tribunal in the matter O.A. No. 138 of 2016 and O.A. No. 139 of 2016 titled Stench Grips Mansa's Sacred Ghaggar River (Suo-Motu case).

Please find enclosed herewith the report of District Level Special Task Force for the month of October and November, 2019 for information & further necessary action please.

CHANDIGARH

Yours sincerely,

*Vijay*  
Member Secretary  
District Level Special Task Force  
o/c

Endst. No. CPCC/2019/3771-3776

Dated: 08.01.2020

A copy is forwarding to the following alongwith monthly report for information and necessary action please.

1. The Chairman, Executive Committee, Executive Committee (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
2. Sh. Babu Ram, Member of Executing Committee, (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
3. Sh. J. Chandra Babu, Additional Director (Scientist 'E'), WQM-1, Central Pollution Control Board and Member of Executing Committee, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
4. Sh. A. Sudhakar, Divisional Head, WQM-I, Central Pollution Control Board, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
5. Ms. Urvashi Gulati, IAS, Member of Executing Committee, (Ghaggar River), kothi no. 82, Sector-11, Chandigarh
6. The Member Secretary, State Level Special Task Force, Chandigarh Pollution Control Committee, Chandigarh.

Yours sincerely,

*Vijay*  
Member Secretary  
District Level Special Task Force

## **MONTHLY REPORT FOR THE MONTH OF NOVEMBER, 2019**

### **SUBMITTED BY DISTRICT LEVEL SPECIAL TASK FORCE**

The 16<sup>th</sup> Meeting of District Level Special Task Force was held on 29.11.2019 under the Chairmanship of Additional Deputy Commissioner, U.T. Chandigarh in D.C. Office, Chandigarh to discuss the action taken to control the pollution in river Ghaggar.

#### **1) Status of tenders w.r.t. upgradation of STPs and construction of new STPs.**

Sh. Gagandeep Singh, Manager, Chandigarh Smart City Limited, informed that two bids were received by Chandigarh Smart City Limited for up gradation of existing STPs and construction of new STP. Technical evaluation of bids has been completed but objections were raised in the house. However, the details are yet to be received.

He further informed that the timeline for upgradation of existing STPs and construction of new STPs was November, 2021 but now it has been revised to April, 2022.

#### **2) Status of plugging of various points of Sukhna choe and N-choe.**

Sh. Vivek Pandey informed the committee that some of the points which were plugged earlier are again found discharging wastewater into the choes. Status of all the discharge points of Sukhna Choe, N-Choe & Faida Choe were discussed. Municipal Corporation, Chandigarh provided the status of discharge of untreated waste water in N-Choe, Sukhna choe and Faida choe which is as given below:

#### **STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE**

<b>Sr. No.</b>	<b>Point</b>	<b>Status as on September 2018</b>	<b>Action Plan</b>	<b>Present Status</b>
1	Kishangarh Outlet	There was sewage water discharge from the outlet.	STP was proposed to treat the waste water (To be commissioned by April, 2022).	Plugged
2	Outlet of Village Kishangarh inside Forest Nursery		Chandigarh Administration was to tap the same by 31.03.2019.	



3	Outlet of Shastri Nagar	There was sewage water discharge.	-	Plugged
4.	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	There was sewage water discharge at first outlet of Bapu Dham near bridge on the road connecting IT Park	-	Earlier it was plugged but as found on 14.11.2019, waste water was flowing in the choe. As per MC, Chd, work of plugging is under progress and will be completed by 30.12.2019.
5.	Second outlet of Bapu Dham Colony (Known as Madrasi Colony)	There was sewage water discharge at second outlet of Bapu Dham colony	Municipal Corporation Chandigarh had stopped all such discharge points and there is no waste water discharge.	Earlier it was plugged but as found on 14.11.2019, waste water started flowing in the choe.
6.	Outlet from back of Gaushala near C & D Plant, Industrial Area, Phase-I, Chd.	There was substantial sewage discharge from back of Gaushala, Industrial Area, Phase-I, Chd.	-	Plugged
7.	Outlet behind Goshalla near bridge, Industrial Area, Phase-I, Chd.	-	-	This is the new point found on dated 14.11.2019.
8.	Outlet behind CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	There was sewage discharge at the outlet near CTU workshop.	-	Waste water was flowing in the choe as found on 14.11.2019.
9.	Indl. Area, Phase - I, Colony No. 4.	There was discharge from many outlets from Indl. Area,	-	Work has been allotted to the agency which is in progress and will be

		Phase - I, Colony No. 4.		completed by 15.12.2019.
10.	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase - I, Chandigarh.	In case of Non-operation of pump, waste water directly went to Sukhna Choe on regular basis.	-	As found on 14.11.2019, waste water was flowing in the choe as the motor was not running since 06.11.2019. As per MC, Chd, now it has been rectified.
11.	Outlet of Village Hallomajra	There was substantial sewage discharge from the outlet of Village Hallomajra.	By 31.01.2019 all the household were to be connected to sewer line.	The discharge near Village Hallomajra was from 2 points:- Ordinance cable factory was found discharging sewer in storm drainage lines which has been stopped. Nearly 80% of the sewer connections have been given to the newly laid sewer line at Village Hallomajra and Deep Complex. Work in balance 20% is in progress.
12.	Village Daria	There was discharge of sewage water from Village Daria	-	Rectified
13.	Points adjacent to Kali Mata Mandir near Industrial Area Phase-II Chd.	-	-	The work of cleaning of sewerage lines has been completed. The sewage at this point is coming from : 1.Ram Darbar 2.Hallomajra 3.From Tribune Chowk 4.Sector 42 (Shanti Path) on wards a) The flow of sewage from Ram Darbar, Hallomajra has been reduced and will be plugged by 15/01/2020. b) The flow of sewage

			from Tribune Chowk, Sector 42 (Shanti Path) onwards will be plugged by 31/03/2020.
--	--	--	------------------------------------------------------------------------------------

**STATUS OF UNTREATED WASTE WATER DISCHARGE IN N- CHOE**

Sr. No.	Point	Status as on September 2018	Action Plan	Present Status
1	Bougainvillea Garden	One Outlet was discharging from MLA hostel side.	-	Plugged
2	Leisure valley	02 outlets were discharging waste water	One Outlet has been plugged and there is little discharge from one outlet, will be plugged by 31.12.2018.	Plugged
3	Near red cross (Madhya Marg)	01 outlet was discharging waste water	-	Earlier it was plugged but as on 18.11.2019, fresh water was flowing in the choke.
4	Sec 23 near B.D Hospital (Neuro Psychiatry)	01 outlet was discharging waste water	-	Plugged
5	Bal Bhawan side	Very less discharge	-	Plugged
6	MCM DAV	One outlet was discharging sewage water.	-	Plugged
7.	Bridge point near beant memorial	-	-	As on dated 18.11.2019, wastewater was flowing in the choke but it has been plugged as found on dated 25.11.2019.



				completed by 15.11.2019
11.	Village Daria	There was discharge of sewage water from Village Daria	-	Rectified

**STATUS OF UNTREATED WASTE WATER DISCHARGE IN FAIDA CHOE**

Sr. No.	Point	Status as on September, 2018	Action Plan	Present status
1.	Points adjacent to Kali Mata Mandir near Industrial Area Phase-II Chd.	<p>The sources of discharge of sewage have been identified and the work will be taken in hand shortly.</p> <p>A sewer line of 24" x36" size from Bapudham to STP at 3BRD is blocked, the tenders for clearing the blockage through Super Suction Machine were invited but only single eligible bid was received. The tenders were re-invited and opened on 11.7.2019. However, again single eligible bid has been received. Now, short term tenders have been invited for the 3<sup>rd</sup> time, to be opened on 17.7.2019 and work is likely to be taken in hand shortly.</p> <p>Major point of untreated sewer entering the storm water drain has been identified near 3BRD chowk where manhole is damaged. The tenders for the repair of same have been invited to be opened on 26.07.2019.</p> <p>The flow of untreated sewage to the choe adjacent in the 3BRD STP is likely to be stopped by 30.06.2020.</p>	-	<p>The work is under process and line shall be workable by 15.11.2019.</p> <p>Rectified.</p> <p>Major source has been identified and tapping of the sewer shall be completed by 30.6.2020.</p>

### **3) Status of health check up camps**

Ms. Shobhna Pathania, Nodal Officer, Health Department informed that as per the directions, regular health check up camps are being organized. Last health check up camp was organized on 18.9.2019 at Civil Dispensary, Sarangpur. Due to some technical lag, they did not organize any camp in the month of October and next health check up camp will be organized on 06.11.2019 at Khajehri, Chandigarh.

Sh. Sachin Rana, ADC, UT Chandigarh directed Health department, U.T. Chandigarh to organize health camps with an objective to prevent water borne diseases and the main focus should be on imparting awareness amongst localities.

MC Official suggested Bapu dham colony as a location for next health camp. ADC has also directed CPCC to provide them with the list of locations where Health Department may organize the health camps.

#### **4) Inspection of industries by Additional Chief inspector of factories w.r.t. compliance of the factory rules to provide good environment and healthy condition to the workers of the factories.**

Sh. Sushil Dogra informed the committee that the report submitted by the Additional Chief inspector of factories in the meeting of Executive Committee was not satisfactory and he was directed to submit the modified report again w.r.t. observations, action taken, work zone area, display boards, safety gears, chemical storage, air emissions and ventilation etc.

ADC directed to call Additional Chief inspector of factories for the next meeting.

#### **5) Regular inspection of industries by CPCC so as to take action against the defaulting units.**

Sh. Sushil Dogra informed the committee that inspections of industries are being done regularly and actions are being taken as per the findings. He informed that 13 units were inspected in the month of September. Out of which samples were collected from 10 units. 11 units were found to be complying with the standards whereas directions for disconnection of electricity were issued to 2 non-complying units.

In the end ADC directed all the concerned to take action as per the action plan and directions of Hon'ble N.G.T. and Executive Committee.