



Chandigarh Pollution Control Committee

Paryavaran Bhawan, Madhya Marg, Sector 19-B, Chandigarh-160 019

No. CPCC/2019/3770

Dated: 08.01.2020

To

The Chairman-cum-Advisor to the Administrator,
State Level Special Task Force,
U.T. Chandigarh

Sub:- Submission of Monthly report of District Level Special Task Force regarding.

Sir,

This is in reference to order dated 7th August, 2018 passed by Hon'ble National Green Tribunal in the matter O.A. No. 138 of 2016 and O.A. No. 139 of 2016 titled Stench Grips Mansa's Sacred Ghaggar River (Suo-Motu case).

Please find enclosed herewith the report of District Level Special Task Force for the month of October and November, 2019 for information & further necessary action please.

Yours sincerely,

Member Secretary
District Level Special Task Force

Endst. No. CPCC/2019/3771-3776

Dated: 08.01.2020

A copy is forwarding to the following alongwith monthly report for information and necessary action please.

1. The Chairman, Executive Committee, Executive Committee (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
2. Sh. Babu Ram, Member of Executing Committee, (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
3. Sh. J. Chandra Babu, Additional Director (Scientist 'E'), WQM-1, Central Pollution Control Board and Member of Executing Committee, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
4. Sh. A. Sudhakar, Divisional Head, WQM-I, Central Pollution Control Board, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
5. Ms. Urvashi Gulati, IAS, Member of Executing Committee, (Ghaggar River), kothi no. 82, Sector-11, Chandigarh
6. The Member Secretary, State Level Special Task Force, Chandigarh Pollution Control Committee, Chandigarh.

Yours sincerely,

Member Secretary
District Level Special Task Force

MONTHLY REPORT FOR THE MONTH OF OCTOBER, 2019

SUBMITTED BY DISTRICT LEVEL SPECIAL TASK FORCE

The 15th Meeting of District Level Special Task Force was held on 31.10.2019 under the Chairmanship of Additional Deputy Commissioner, U.T. Chandigarh in D.C. Office, Chandigarh to discuss the action taken to control the pollution in river Ghaggar.

1) Status of tenders w.r.t. upgradation of STPs and construction of new STPs.

Sh. Gagandeep Singh, Manager, Chandigarh Smart City Limited, informed that two bids were received by Chandigarh Smart City Limited for up gradation of existing STPs and construction of new STP. Technical evaluation of bids is under process and will be completed by November, 2019.

He further informed that the timeline for upgradation of existing STPs and construction of new STPs has also been revised to April, 2022. They have submitted a copy of the affidavit submitted by MCC to Hon'ble NGT for the revision of timeline w.r.t upgradation of existing STPs.

2) Status of plugging of various points of Sukhna choe and N-choe.

Status of all the discharge points of Sukhna Choe, N-Choe & Faida Choe were discussed. Municipal Corporation, Chandigarh provided the status of discharge of untreated waste water in N-Choe, Sukhna choe and Faida choe which is as given below:

STATUS OF UNTREATED WASTE WATER DISCHARGE IN N-CHOE

Sr. No.	Point	Status as on September, 2018	Action plan	Present status
1.	Bougainvillea Garden	One Outlet was discharging from MLA hostel side. However fresh water is being discharged.	-	Plugged
2.	Leisure valley	02 outlets were discharging waste water	One Outlet has been plugged and there is little discharge from one outlet, will be plugged by 31.12.2018.	Plugged
3.	Near red cross (Madhya Marg)	01 outlet was discharging waste water	-	Plugged

4.	Sec 23 near B.D Hospital (Neuro Psychiatry)	01 outlet was discharging waste water	-	Plugged
5.	Bal Bhawan side	Very less discharge	-	Plugged
6.	MCM DAV	One outlet of sewage water was being discharged.	-	Plugged
7	01 outlet in Beant Memorial	Water logging	This is major work and will be completed by August, 2019.	Construction work completed, however connection likely to be restored within 15 days after strengthening of structure.
8.	Bridge point near beant memorial	-	-	
7.	Sector 52 (starting)	Two outlets were discharging Sewage Water	The work will be taken care when the work of Beant Memorial Outlet will be completed (Will be plugged by 31.12.2019).	Work is in progress
8.	Sector 52 (End)	Two outlets were discharging Sewage Water	One outlet has been plugged and another outlet will be plugged by 31.12.2019.	
9.	One outlet coming from Sec 51	Sewage Water was being discharged	-	Plugged
10.	Sector 36 starting point near Central Forensic Science Laboratory	One outlet from CFSL side was discharging in N-Choe and due to some technical snag, tertiary treated water line is releasing water into N-choe.	-	Plugged
11.	Sector 10 points	One outlet where fresh water was being discharged	-	Plugged
12.	Rose Garden	02 outlets were discharging Waste water	-	Plugged
13.	Shanti Kunj Garden	Waste water was being discharged	-	Plugged
14.	Sector 23 Traffic Park	Waste water was being discharged	-	Plugged
15.	Sector 23 End Point	There are four discharge points. Sewage water was being discharged from three outlets.	-	Plugged
16.	Attawa	02 points were discharging sewage water	-	Major points have been detected in Sector-37

		into N-Choe.		Chandigarh. Same shall be rectified by 30.11.2019.
17.	Sector 53 point near furniture market	One outlet of sewage water was being discharged.	-	The necessary repairs have been carried out, however the connection have not been made as the 2 no. new RCC manholes are yet to be commissioned. And work will be completed by 30.11.2019.
18.	Sector 53 point in Gardens of springs	One outlet of sewage water in huge quantity was being discharged (Adarsh Colony).	-	The work for diversion of sewerage at Sector-55 has been completed. Only 20% of the wastewater of Aadarsh colony (slum) has to be tapped. Geological survey has been completed and technical proposal is under process to tap this balanced sewer.

STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE

Sr. No.	Point	Status as on September, 2018	Action Plan	Present status
1.	Kishangarh Outlet	There was sewage water discharge from the outlet.	STP was proposed to treat the waste water (To be commissioned by Nov. 2021)	Plugged
2.	Outlet of village Kishangarh inside forest nursery	There was sewage water discharge from the outlet.	Chandigarh Administration was to tap the same by 31.03.2019	Plugged
3.	Outlet of Shastri Nagar	There was sewage water discharge.	-	Plugged
4.	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	There was sewage water discharge at first outlet of Bapu Dham near bridge on the road connecting IT Park	-	Fresh sewage started flowing in the Choe and will be plugged by 30.12.2019.

5.	Second outlet of Bapu Dham Colony (Known as Madras Colony)	There was sewage water discharge at second outlet of Bapu Dham colony	Municipal Corporation Chandigarh had stopped all such discharge points and there is no waste water discharge.	Plugged
6.	Outlet from back of Gaushala, Industrial Area, Phase-I, Chd.	There was substantial sewage discharge from back of Gaushala, Industrial Area, Phase-I, Chd.	-	Plugged
7.	Outlet near CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	There was sewage discharge at the outlet near CTU workshop.	-	Plugged
8.	Indl. Area, Phase – I, Colony No. 4.	There was discharge from many outlets from Indl. Area, Phase – I, Colony No. 4.	-	Work has been allotted to the agency which is in progress and same shall be completed by 15.11.2019.
9.	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase – I, Chandigarh.	In case of Non-operation of pump, waste water directly went to Sukhna Choe on regular basis.	-	Rectified
10.	Outlet of Village Hallomajra	There was substantial sewage discharge from the outlet of Village Hallomajra.	By 31.01.2019 all the household were to be connected to sewer line.	<p>Open channel waste water has been rectified.</p> <p>Ordinance cable factory has been still found discharging their waste water into storm water drainage line. However, 40% of the sewage has been found reduced by Ordinance cable factory. Sewage water discharge shall be stopped by 31.12.2019.</p> <p>95% of the work for providing new sewerage connection has been completed; remaining residents who have not obtained sewer connection has been served with notices. The work is likely to be</p>

8.	Bridge point sec-42 (girls college side)	-	-	As on dated 18.11.2019, wastewater was flowing in the choe.
9.	Attawa	02 points were discharging sewage water into N-Choe.	-	Major points have been detected in Sector 25, 37, 38 Chandigarh. Same shall be rectified by 31.01.2020 as the tender for laying of new sewerage lines for Sector 38 A, Chandigarh has been called and work will be got completed by 31/01/2020.
10.	Sector 53 point near furniture market	One outlet was discharging sewage water	-	Plugged
11.	Sector 53 point in Gardens of springs	One outlet was discharging sewage water in huge quantity (Adarsh Colony).	-	The work of diversion of sewerage at Sector 55 has been completed. Only 20% of the waste water of Aadarsh Colony (Slum) has to be tapped to stopped. Topographical survey has been completed, technical proposal is under process to tap this balanced sewer

3) Status of health check up camps

Ms. Shobhna Pathania, Nodal Officer, Health Department informed that as per the directions, regular health check up camps are being organized. Last health check up camp was organized on 6.11.2019 at Civil Dispensary, Kajheri.

4) Inspection of industries by Additional Chief inspector of factories w.r.t. compliance of the factory rules to provide good environment and healthy condition to the workers of the factories.

Sh. Vivek Pandey informed the committee that the report submitted by the Additional Chief inspector of factories in the meeting of Executive Committee was not satisfactory and they were directed to submit the modified report again which has not been submitted yet.

A.D.C directed the Additional Chief inspector of factories to submit the report w.r.t. randomly selected larger units within a week time.

5) Regular inspection of industries by CPCC so as to take action against the defaulting units.

Sh. Vivek Pandey informed the committee that inspections of industries are being done regularly and actions are being taken as per the findings. He informed that 12 units were inspected in the month of October. Show cause notices were issued to 3 non- complying units.

A.D.C. directed to organize a skill development program to train the workers employed in the industrial units w.r.t. various processes used in industries.

Sh. Vivek Pandey informed that as per the directions of Hon'ble NGT, Advisor to the Administrator has to personally appear before the NGT on 10.01.2020 and present the status of implementation of various directions of Hon'ble NGT. Hence, all the agencies should work in a way so as to avoid any inconvenient situation.

A.D.C directed to write letter to the MCC regarding irregular functioning of STPs and discharge of untreated sewage water into the choes.

In the end, A.D.C directed all the concerned to take action as per the action plan and directions of Hon'ble N.G.T. and Executive Committee.