



Chandigarh Pollution Control Committee

Paryavaran Bhawan, Madhya Marg, Sector 19-B, Chandigarh-160 019

No. CPCC/2020/ 4801

Dated: 06/03/2020

To

The Chairman-cum-Adviser to the Administrator,
State Level Special Task Force,
U.T. Chandigarh

Sub:- Submission of Monthly report of District Level Special Task Force regarding.

Sir,

This is in reference to order dated 7th August, 2018 passed by Hon'ble National Green Tribunal in the matter O.A. No. 138 of 2016 and O.A. No. 139 of 2016 titled Stench Grips Mansa's Sacred Ghaggar River (Suo-Motu case).

Please find enclosed herewith the report of District Level Special Task Force for the month of February, 2020 for information & further necessary action please.

Yours sincerely,

CHANDIGARH

Member Secretary
District Level Special Task Force

Endst. No. CPCC/2020/ 4802-4807

Dated: 06/03/2020

A copy is forwarding to the following alongwith monthly report for information and necessary action please.

1. The Chairman, Executive Committee, Executive Committee (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
2. Sh. Babu Ram, Member of Executing Committee, (Ghaggar River), 4th Floor, Tower No. 5, Forest Complex, Sector 68, Mohali.
3. Sh. J. Chandra Babu, Additional Director (Scientist 'E'), WQM-1, Central Pollution Control Board and Member of Executing Committee, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
4. Sh. A. Sudhakar, Divisional Head, WQM-I, Central Pollution Control Board, Parivesh Bhawan, East Arjun Nagar, Delhi - 110032.
5. Ms. Urvashi Gulati, IAS, Member of Executing Committee, (Ghaggar River), kothi no. 82, Sector-11, Chandigarh
6. The Member Secretary, State Level Special Task Force, Chandigarh Pollution Control Committee, Chandigarh.

Yours sincerely,

Member Secretary
District Level Special Task Force

MONTHLY REPORT FOR THE MONTH OF FEBRUARY, 2020

SUBMITTED BY DISTRICT LEVEL SPECIAL TASK FORCE

The 18th Meeting of District Level Special Task Force was held on 19.2.2020 under the Chairmanship of Sh. Sachin Rana, Additional Deputy Commissioner, U.T. Chandigarh, in D.C. Office, Chandigarh to discuss the action taken to control the pollution in river Ghaggar.

1) Status of tenders w.r.t. upgradation of STPs and construction of new STPs.

Sh. Sanjay Sahni, XEN, Municipal Corporation, Chandigarh informed that the process of tendering is undergoing and work commencement will be done by 31.3.2020.

Sh. Satwant Singh, Chandigarh Smart City Limited informed that their technical committee meeting is going to be held today i.e. 19.2.2020 and also informed that they are trying their best to speed up the process. However, Sh. Vivek Pandey informed that as per the schedule provided by Chandigarh Smart City Limited, work commencement will be done by May, 2020, which is beyond the timeline provided by the Hon'ble National Green Tribunal.

Chairman, Sh. Sachin Rana, Additional Deputy Commissioner, U.T. Chandigarh directed the Chandigarh Smart City Limited to expedite the process and work commencement should be done by 31.3.2020.

2) As per the directions of Hon'ble NGT in its order dated 20.01.2020 in the O.A No. 593/2017 in the matter O.A. No. 138 of 2016 and O.A. No. 139 of 2016 titled "Stench Grips Mansa's Sacred Ghaggar River", the Hon'ble NGT has recommended that suitable arrangements by the Municipal Corporation, Chandigarh shall be made to disinfect the treated sewage of STPs to bring the Faecal coliform parameter within the prescribed norms.

As per the directions of Hon'ble NGT in its order dated 28.8.2019 in the O.A. No. 593/2017 in the matter of Paryavaran Suraksha Samiti Vs. Union of India, the Hon'ble NGT has directed all the local Bodies and or the concerned departments of the State Government to ensure 100% treatment of the generated sewage and in default to pay compensation which is to be recovered by the States/UTs, with effect from 01.04.2020.

Sh. Vivek Pandey, Scientist B, CPCC informed the members that as per the order of Hon'ble NGT, environmental compensation is to be imposed on STPs for non-compliance in terms of quality of treated wastewater and specifically mentioned about the faecal coliforms. He also informed that as per the latest test reports of January, 2020, four out of

six STPs are not meeting with the desired norms w.r.t B.O.D. and w.r.t faecal coliforms, none of the STP is meeting with the prescribed norms. Therefore, from 1.04.2020 onwards, Chandigarh Pollution Control Committee has no other option than to impose environmental compensation for non-compliance of STPs.

Sh. Vijay Premi, XEN, M.C. Chandigarh informed that they have already initiated the process of treatment of coliforms and by 31.3.2020, coliform treatment process will be in place and all the STPs will meet with the prescribed norms.

3) Status of plugging of various points of Sukhna Choe and N-Choe.

Sh. Vivek Pandey informed the committee that many points discharging wastewater into the drains have been plugged. Status of all the discharge points of Sukhna Choe and N-Choe was discussed. Municipal Corporation, Chandigarh provided the status of discharge of untreated waste water in N-Choe and Sukhna choe which is as given below:

STATUS OF UNTREATED WASTE WATER DISCHARGE IN SUKHNA CHOE

Sr. No.	Point	Status as on September 2018	Action Plan	Present Status
1	Kishangarh Outlet	There was sewage water discharge from the outlet.	STP was proposed to treat the waste water (To be commissioned by April, 2022).	Plugged
2	Outlet of Village Kishangarh inside Forest Nursery		Chandigarh Administration was to tap the same by 31.03.2019.	
3	Outlet of Shastri Nagar	There was sewage water discharge.	-	Plugged
4.	First outlet of Bapu Dham near bridge on the road connecting IT park with Sector 26, Chandigarh	There was sewage water discharge at first outlet of Bapu Dham near bridge on the road connecting IT Park	-	Work under progress and will be completed by 28.2.2020.

5.	Second outlet of Bapu Dham Colony (Known as Madrasi Colony)	There was sewage water discharge at second outlet of Bapu Dham colony	Municipal Corporation Chandigarh had stopped all such discharge points and there is no waste water discharge.	Plugged
6.	Outlet from back of Gaushala, Industrial Area, Phase-I, Chd. (Inside Forest Area)	There was substantial sewage discharge from back of Gaushala, Industrial Area, Phase-I, Chd.	-	Plugged
7.	Outlet behind Goshalla near bridge, Industrial Area, Phase-I, Chd.	-	-	Plugged
8.	Outlet behind CTU workshop Industrial Area, Phase-I, Chd. (Inside Forest Area)	There was sewage discharge at the outlet near CTU workshop.	-	Plugged
9.	Outlet from industrial area side (inside forest area)	-	-	Plugged
10.	Indl. Area, Phase - I, Colony No. 4.	There was discharge from many outlets from Indl. Area, Phase - I, Colony No. 4.	-	Plugged.

11.	Pump House operated by Municipal Corporation behind Central Poultry Development Organization, Indl. Area, Phase - I, Chandigarh.	In case of Non-operation of pump, waste water directly went to Sukhna Choe on regular basis.	-	Plugged.
12.	Outlet of Village Hallomajra	There was substantial sewage discharge from the outlet of Village Hallomajra.	By 31.01.2019 all the household were to be connected to sewer line.	Plugged
13.	Village Daria	There was discharge of sewage water from Village Daria	-	Plugged

STATUS OF UNTREATED WASTE WATER DISCHARGE IN N- CHOE

Sr. No.	Point	Status as on September 2018	Action Plan	Present Status
1	Bougainvillea Garden	One Outlet was discharging from MLA hostel side.	-	Plugged
2	Leisure valley	02 outlets were discharging waste water	One Outlet has been plugged and there is little discharge from one outlet, will be plugged by 31.12.2018.	Plugged
3	Near red cross (Madhya Marg)	01 outlet was discharging waste water	-	Plugged
4.	Rose garden	02 outlets were discharging Waste water		Plugged

5.	Shanti kunj	Waste water was being discharged		Plugged
6.	Sec 23 near B.D Hospital (Neuro Psychiatry)	01 outlet was discharging waste water	-	Plugged
7.	Sec 23 traffic park	Waste water was being discharged	-	Plugged
8.	Sec 23 end point	There are four discharge points. Sewage water was being discharged from three outlets	-	Plugged
9.	Sector 36 starting point near Central Forensic Science Laboratory	One outlet from CFSL side was discharging in N-Choe and due to some technical snag, tertiary treated water line is releasing water into N-choe.	-	Plugged
10.	MCM DAV	One outlet was discharging sewage water.	-	Plugged
11.	Bridge point near beant memorial	-	-	Plugged
12.	Bridge point sec-42 (girls college side)	-	-	Plugged
13.	Attawa	02 points were discharging sewage water into N-Choe.	-	Major points have been detected in Sector 25, 37, 38 Chandigarh.

				Sewer lines already laid and connections are being done which will be completed by 28.2.2020.
14.	Sector 53 point near furniture market	One outlet was discharging sewage water	-	Plugged
15.	Sector 53 point in Gardens of springs	One outlet was discharging sewage water in huge quantity (Adarsh Colony).	-	Plugged

4) Status of health check up camps with an objective to prevent water borne diseases.

It was informed that no health camp was organized in the months of January and February, 2020.

5) Regular inspection of industries by CPCC and DLSTF.

Sh. Vivek Pandey informed that DLSTF has conducted 1 no. field visit in the month of January, 2020 and actions have been initiated against the violating units. He further informed that as per the directions of the Executing Committee, inspections of water polluting industries are being done and actions are being taken as per the findings.